

INTERNATIONAL STANDARD

**ISO
5801**

First edition
1997-06-01

Industrial fans — Performance testing using standardized airways

iTeh STANDARD PREVIEW

(standard.iteh.ai) *Ventilateurs industriels — Essais aérauliques sur circuits normalisés*

ISO 5801:1997

<https://standards.iteh.ai/catalog/standards/sist/995a0191-cdeb-4122-ba51-797e3b3a44b6/iso-5801-1997>



Reference number
ISO 5801:1997(E)

Contents

	Page
1 Scope.....	1
2 Normative references.....	1
3 Definitions	2
4 Symbols and units	8
4.1 Symbols.....	8
4.2 Subscripts.....	12
5 General	12
6 Instrumentation for pressure measurement	13
6.1 Barometers.....	13
6.2 Manometers	13
6.3 Damping of manometers.....	14
6.4 Checking of manometers	14
6.5 Position of manometers	14
7 Determination of average pressure in an airway.....	14
7.1 Methods of measurement.....	14
7.2 Use of wall tapings	14
7.3 Construction of tapings	15
7.4 Position and connections.....	15
7.5 Checks for compliance	15
7.6 Use of Pitot-static tube.....	16
8 Measurement of temperature.....	16
8.1 Thermometers.....	16
8.2 Thermometer location	16
8.3 Humidity	17

© ISO 1997

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

International Organization for Standardization
Case postale 56 • CH-1211 Genève 20 • Switzerland
Internet central@iso.ch
X.400 c=ch; a=400net; p=iso; o=isocs; s=central

Printed in Switzerland

9	Measurement of rotational speed	17
9.1	Fan shaft speed	17
9.2	Examples of acceptable methods	17
10	Determination of power input.....	18
10.1	Measurement accuracy.....	18
10.2	Fan shaft power	18
10.3	Determination of fan shaft power by electrical measurement	18
10.4	Impeller power	19
10.5	Transmission systems.....	19
11	Measurement of dimensions and determination of areas.....	19
11.1	Flow measurement devices	19
11.2	Tolerance on dimensions	19
11.3	Determination of cross-sectional area.....	19
12	Determination of air density, humid gas constant and viscosity .	20
12.1	Density of the air in the test enclosure, gas constant for humid air and average density in a section x	20
12.2	Determination of vapour pressure.....	20
12.3	Determination of air viscosity.....	21
13	Determination of flowrate.....	23
13.1	General.....	23
13.2	In-line flowmeters (standard primary devices)	23
13.3	Traverse methods	24
14	Calculation of test results	25
14.1	General	25
14.2	Units	25
14.3	Temperature.....	26
14.4	Mach number and reference conditions	27
14.5	Fan pressure.....	31
14.6	Calculation of stagnation pressure at a reference section of the fan from gauge pressure p_{ex} measured at a section x of the test duct	32
14.7	Inlet volume flowrate	34
14.8	Fan air power and efficiency	34
14.9	Simplified calculation methods.....	39
15	Rules for conversion of test results.....	43
15.1	Laws on fan similarity.....	44
15.2	Conversion rules.....	44
16	Fan characteristic curves	49
16.1	General	49

16.2	Methods of plotting.....	49
16.3	Characteristic curves at constant speed.....	49
16.4	Characteristic curves at inherent speed.....	49
16.5	Characteristic curves for adjustable-duty fan.....	49
16.6	Complete fan characteristic curve.....	50
16.7	Test for a specified duty.....	50
17	Uncertainty analysis.....	51
17.1	Principle.....	51
17.2	Pre-test and post-test analysis.....	52
17.3	Analysis procedure.....	52
17.4	Propagation of uncertainties.....	53
17.5	Reporting uncertainties.....	53
17.6	Maximum allowable uncertainties measurement.....	53
17.7	Maximum allowable uncertainty of results.....	54
18	Selection of test method.....	54
18.1	Classification.....	54
18.2	Installation types.....	54
18.3	Test report.....	56
18.4	User installations.....	56
18.5	Alternative methods.....	56
18.6	Duct simulation.....	56
19	Installation of fan and test airways.....	56
19.1	Inlets and outlets.....	56
19.2	Airways.....	56
19.3	Test enclosure.....	57
19.4	Matching fan and airway.....	57
19.5	Outlet area.....	57
20	Carrying out the test.....	57
20.1	Working fluid.....	57
20.2	Rotational speed.....	57
20.3	Steady operation.....	57
20.4	Ambient conditions.....	57
20.5	Pressure readings.....	58
20.6	Tests for a specified duty.....	58
20.7	Tests for a fan characteristic curve.....	58
20.8	Operating range.....	58
21	Determination of flowrate.....	58
21.1	ISO Venturi nozzle.....	58

21.2	Multiple nozzle or Venturi nozzle	58
21.3	Quadrant inlet nozzle	58
21.4	Conical inlet	58
21.5	Orifice plate	58
21.6	Pitot-static tube traverse	59
22	Determination of flowrate using ISO Venturi nozzle	59
22.1	Geometric form	59
22.2	Venturi nozzle in free-inlet condition.....	59
22.3	Nozzle performance	59
22.4	Uncertainties	64
23	Determination of flowrate using multiple nozzles or Venturi nozzle.....	65
23.1	Installation	65
23.2	Geometric form	65
23.3	Inlet zone	66
23.4	Multiple-nozzle and Venturi-nozzle characteristics	66
23.5	Uncertainty	68
24	Determination of flowrate using a quadrant inlet nozzle	68
24.1	Installation	68
24.2	Geometric form	69
24.3	Unobstructed space in front of inlet nozzle.....	69
24.4	Quadrant inlet nozzle performance	70
24.5	Uncertainty	70
25	Determination of flowrate using a conical inlet	70
25.1	Geometric form	70
25.2	Screen loading	70
25.3	Inlet zone	71
25.4	Conical inlet performance.....	71
25.5	Uncertainties	72
26	Determination of flowrate using an orifice plate	73
26.1	Installation	73
26.2	Orifice plate	73
26.3	Ducts	77
26.4	Pressure tapplings.....	77
26.5	Calculation of mass flowrate	77
26.6	Reynolds number	78
26.7	In-duct orifice with D and $D/2$ taps.....	78
26.8	In-duct orifice with corner taps.....	80
26.9	Outlet orifice with wall tapplings.....	80

26.10	Inlet orifice with corner taps	83
26.11	Inlet orifice with wall tappings.....	86
27	Determination of flowrate using a Pitot-static tube traverse	86
27.1	General	86
27.2	Pitot-static tube	86
27.3	Limits of air velocity	91
27.4	Location of measurement points	91
27.5	Determination of flowrate	92
27.6	Flowrate coefficient	92
27.7	Uncertainty of measurement	93
28	Installation categories and setups	93
28.1	Type A: free inlet and free outlet	93
28.2	Type B: free inlet and ducted outlet.....	93
28.3	Type C: ducted inlet and free outlet.....	93
28.4	Type D: ducted inlet and ducted outlet.....	94
28.5	Test installation type	94
29	Component parts of standardized airways.....	94
29.1	Symbols.....	94
29.2	Component parts	94
29.3	Flowrate measurement devices.....	97
30	Common airway segments for ducted fan installation.....	98
30.1	Common segments	98
30.2	Common segment at fan outlet.....	98
30.3	Common segment at fan inlet	101
30.4	Outlet duct simulation.....	103
30.5	Inlet duct simulation.....	103
30.6	Loss allowances for standardized airways.....	104
31	Standardized test chambers.....	107
31.1	Test chamber	107
31.2	Variable supply and exhaust systems	111
31.3	Standardized inlet test chambers.....	111
31.4	Standardized outlet test chambers	114
32	Standard methods with test chambers — type A installations ...	115
32.1	Types of fan setup	115
32.2	Inlet-side test chambers.....	115
32.3	Outlet-side test chambers.....	130
33	Standard methods with outlet-side test ducts — type B installations.....	138
33.1	Types of fan setup	138

33.2	Outlet-side test ducts with antiswirl — device	138
33.3	Outlet chamber test ducts without antiswirl — device....	153
34	Standard methods with inlet-side test ducts or chambers — Type C installations.....	161
34.1	Types of fan setup.....	161
34.2	Inlet-side test ducts.....	162
34.3	Inlet-side test chambers.....	175
35	Standard methods with inlet- and outlet-side test ducts — type D installations	189
35.1	Types of fan setup.....	189
35.2	Installation type B with outlet antiswirl device and inlet duct or inlet-duct simulation	193
35.3	Installation type B without outlet antiswirl device nor common segment and with inlet duct or inlet-duct simulation	201
35.4	Installation type C with outlet-duct common segment and antiswirl device and common inlet duct.....	204
35.5	Installation type C with outlet-duct simulation without antiswirl device.....	210
Annexes		
A	Fan pressure and fan installation types	220
B	Fan-powered roof exhaust ventilators.....	224
C	Direct calculations of p_{sqn} and p_n at section n of the fan — Installation types B, C and D	226
D	Fan outlet elbow in case of a non-horizontal discharge axis	229
E	Bibliography	232

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

International Standard ISO 5801 was prepared by Technical Committee ISO/TC 117, *Industrial fans*, Subcommittee SC 1, *Fan performance testing using standardized airways*.

Annexes A, B and C form an integral part of this International Standard. Annexes D and E are for information only.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

ISO 5801:1997
<https://standards.iteh.ai/catalog/standards/sist/995a0191-cdeb-4122-ba51-797e3b3a44b6/iso-5801-1997>

Introduction

This International Standard is the result of almost thirty years of discussion, comparative testing and detailed analyses by leading specialists from the fan industry and research organizations throughout the world.

It was demonstrated many years ago that the codes for fan performance testing established in different countries do not always lead to the same results.

The need for an International Standard has been evident for some time and ISO/TC 117 started its work in 1963. Important progress has been achieved over the years and although the International Standard itself was not yet published, the subsequent revisions of various national standards led to much better agreement among them.

It has now become possible to complete this International Standard by agreement on certain essential points. It must be borne in mind that the test equipment, especially for large fans, is very expensive and it was necessary to include in the present International Standard many set-ups from various national codes in order to authorize their future use. This explains the sheer volume of this document.

Essential features of the present standard are as follows:

a) Types of installation

Since the connection of a duct to a fan outlet and/or inlet modifies its performance, it has been agreed that four standard installation types should be recognized.

These are:

- Type A: free inlet and outlet;
- Type B: free inlet and ducted outlet;
- Type C: ducted inlet and free outlet;
- Type D: ducted inlet and outlet.

A fan adaptable to more than one installation type will have more than one standardized performance characteristic. The user should select the installation type closest to his application.

b) Common parts

The differences obtained by testing the same fan according to various test codes depend chiefly on the flow pattern at the fan outlet and, while often minor, can be of substantial significance. There is general agreement that it is essential that all standardized test airways to be used with fans have

portions in common adjacent to the fan inlet and/or outlet sufficient to ensure consistent determination of fan pressure.

Geometric variations of these common segments are strictly limited.

However, conventional agreement has been achieved for some particular situations:

1) For centrifugal or cross-flow fans without outlet swirling flow, it is possible to use a simplified outlet duct as described in 30.2 f) without straightener when discharging to the atmosphere or to a measuring chamber.

2) For large fans (outlet diameter exceeding 800 mm) it may be difficult to carry out the tests with standardized common airways at the outlet including a straightener. In this case, by mutual agreement between the parties concerned, the fan performance may be measured using the set-up described in 30.2 f) with a duct of length $2D$ on the outlet side. Results obtained in this way may differ to some extent from those obtained using the normal type D installation, especially if the fan produces a large swirl. Establishment of a possible value of differences, is still a subject of research.

c) Calculations

Fan pressure is defined as the difference between the stagnation pressure at the outlet of the fan and the stagnation pressure at the inlet of the fan. The compressibility of air must be taken into account when high accuracy is required. However, simplified methods may be used when the reference Mach number does not exceed 0,15.

A method for calculating the stagnation pressure and the fluid or static pressure in a reference section of the fan, which stemmed from the work of the ad hoc group of Subcommittee 1 of ISO/TC 117, is given in annex C.

Three methods are proposed for calculation of the fan power output and efficiency. All three methods give very similar results (difference of a few parts per thousand for pressure ratios equal to 1,3).

d) Flowrate measurement

Determination of flowrate has been completely separated from the determination of fan pressure. A number of standardized methods may be used.

Industrial fans — Performance testing using standardized airways

1 Scope

This International Standard deals with the determination of the performance of industrial fans of all types except those designed solely for air circulation e.g. ceiling fans and table fans.

Estimates of uncertainty of measurement are provided and rules for the conversion, within specified limits, of test results for changes in speed, gas handled and, in the case of model tests, size are given.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

2 Normative references

The following standards contain provisions which, through reference in this text, constitute provisions of this International Standard. At the time of publication, the editions indicated were valid. All standards are subject to revision, and parties to agreements based on this International Standard are encouraged to investigate the possibility of applying the most recent editions of the standards indicated below. Members of IEC and ISO maintain registers of currently valid International Standards.

ISO 3966:1977, *Measurement of fluid flow in closed conduits — Velocity area method using Pitot static tubes.*

ISO 5167-1:1991, *Measurement of fluid flow by means of pressure differential devices — Part 1: Orifice plates, nozzles and Venturi tubes inserted in circular cross-section conduits running full.*

ISO 5168:—¹⁾, *Measurement of fluid flow — Evaluation of uncertainties.*

ISO 5221:1984, *Air distribution and air diffusion — Rules to methods of measuring air flowrate in an air handling duct.*

IEC 34-2:1972, *Rotating electrical machines — Part 2: Methods for determining losses and efficiency of rotating electrical machinery from tests (excluding machines for traction vehicles).*

IEC 51-2:1984, *Direct acting indicating analogue electrical-measuring instruments and their accessories — Part 2: Special requirements for ammeters and voltmeters.*

IEC 51-3:1984, *Direct acting indicating analogue electrical-measuring instruments and their accessories — Part 3: Special requirements for wattmeters and varmeters.*

IEC 51-4:1984, *Direct acting indicating analogue electrical-measuring instruments and their accessories — Part 4: Special requirements for frequency meters.*

1) To be published. (Revision of ISO 5168:1978)

3 Definitions

For the purposes of this International Standard, the definitions given in ISO 5168 and the following definitions apply.

NOTE 1 All the symbols used in this International Standard are listed with their units in clause 4.

3.1 area of the conduit section, A_x : Area of the conduit at section x .

3.2 fan inlet area, A_1 : Surface plane bounded by the upstream extremity of the air-moving device.

The inlet area is, by convention, taken as the gross area in the inlet plane inside the casing.

3.3 fan outlet area, A_2 : Surface plane bounded by the downstream extremity of the air-moving device.

Fan outlet area is, by convention, taken as the gross area in the outlet plane inside the casing.

3.4 temperature, t : Air or fluid temperature measured by a temperature sensor.

3.5 absolute temperature, Θ : Thermodynamic temperature.

$$\Theta = t + 273,15$$

NOTE 2 In this document, Θ represents the absolute temperature and t the temperature in degrees Celsius.

3.6 specific gas constant, R : iTeh STANDARD PREVIEW
(standards.iteh.ai)

For an ideal dry gas, the equation of state is written

$$\frac{p}{\rho} = R\Theta$$

ISO 5801:1997

$R = 287 \text{ J} \cdot \text{kg}^{-1} \cdot \text{K}^{-1}$ for dry air. <https://standards.iteh.ai/catalog/standards/sist/995a0191-cdeb-4122-ba51-797e3b3a44b6/iso-5801-1997>

3.7 isentropic exponent, κ :

For an ideal gas and an isentropic process,

$$\frac{p}{\rho^\kappa} = \text{constant}$$

$\kappa = 1,4$ for atmospheric air.

3.8 specific heat capacity at constant pressure, c_p :

For an ideal gas,

$$c_p = \frac{\kappa}{\kappa - 1} R$$

3.9 specific heat capacity at constant volume, c_v :

For an ideal gas,

$$c_v = \frac{1}{\kappa - 1} R$$

3.10 compressibility factor, Z :

For an ideal gas, $Z = 1$

For a real gas,

$$Z = \frac{p}{\rho R \Theta}$$

and Z is a function of the ratios p/p_c and Θ/Θ_c

where

p_c is the critical pressure of the gas;

Θ_c is the critical temperature of the gas.

3.11 stagnation temperature at a point, Θ_{sg} : Absolute temperature which exists at an isentropic stagnation point for ideal gas flow without addition of energy or heat.

The stagnation temperature is constant along an airway and, for an inlet duct, is equal to the absolute ambient temperature in the test enclosure.

3.12 static or fluid temperature at a point, Θ : Absolute temperature registered by a thermal sensor moving at the fluid velocity.

For a real gas flow,

$$\Theta = \Theta_{sg} - \frac{v^2}{2c_p}$$

where v = fluid velocity at a point, in metres per second ($\text{m} \cdot \text{s}^{-1}$).

In a duct, when the velocity increases the static temperature decreases.

3.13 dry-bulb temperature, t_d : Air temperature measured by a dry temperature sensor in the test enclosure, near the fan inlet or airway inlet.

3.14 wet-bulb temperature, t_w : Air temperature measured by a temperature sensor covered by a water-moistened wick and exposed to air in motion.

When properly measured, it is a close approximation of the temperature of adiabatic saturation.

3.15 stagnation temperature at a section x , Θ_{sgx} : Mean value, over time, of the stagnation temperature averaged over the area of the specified airway cross-section.

3.16 static or fluid temperature at a section x , Θ_x : Mean value, over time, of the static or fluid temperature averaged over the area of the specified airway cross-section.

3.17 absolute pressure at a point; absolute pressure, p : Pressure, measured with respect to absolute zero pressure, which is exerted at a point at rest relative to the air around it.

3.18 atmospheric pressure, p_a : Absolute pressure of the free atmosphere at the mean altitude of the fan.

3.19 gauge pressure, p_e : Value of the pressure when the datum pressure is the atmospheric pressure at the point of measurement.

It may be negative or positive.

$$p_e = p - p_a$$

3.20 absolute stagnation pressure at a point, p_{sg} : Absolute pressure which would be measured at a point in a flowing gas if it were brought to rest via an isentropic process:

$$p_{sg} = p \left(1 + \frac{\kappa - 1}{2} Ma^2 \right)^{\frac{\kappa}{\kappa - 1}}$$

where Ma is the Mach number at this point (see 3.23).

3.21 Mach factor, F_M : Correction factor applied to the dynamic pressure at a point, given by the expression

$$F_M = \frac{p_{sg} - p}{p_d}$$

The Mach factor may be calculated by

$$F_M = 1 + \frac{Ma^2}{4} + \frac{(2 - \kappa) Ma^4}{24} + \frac{(2 - \kappa)(3 - 2\kappa) Ma^6}{192} + \dots$$

3.22 dynamic pressure at a point, p_d : Pressure calculated from the velocity v and the density ρ of the air at the point.

$$p_d = \rho \frac{v^2}{2}$$

3.23 Mach number at a point, Ma : Ratio of the gas velocity at a point to the velocity of sound.

$$Ma = \frac{v}{\sqrt{\kappa R_w \Theta}} = \frac{v}{c}$$

where

c is the velocity of sound,

$$c = \sqrt{\kappa R_w \Theta}$$

R_w is the gas constant of humid gas.

3.24 gauge stagnation pressure at a point, p_{esg} : Difference between the absolute stagnation pressure p_{sg} and the atmospheric pressure p_a .

$$p_{esg} = p_{sg} - p_a$$

3.25 mass flowrate, q_m : Mean value, over time, of the mass of air which passes through the specified airway cross-section per unit of time.

NOTE 3 The mass flow will be the same at all cross-sections within the fan airway system excepting leakage.

3.26 average gauge pressure at a section x , p_{ex} : Mean value, over time, of the gauge pressure averaged over the area of the specified airway cross-section.

3.27 average absolute pressure at a section x , p_x : Mean value, over time, of the absolute pressure averaged over the area of the specified airway cross-section.

$$p_x = p_{ex} + p_a$$

3.28 average density at a section x , ρ_x : Fluid density calculated from the absolute pressure p_x and the static temperature Θ_x .

$$\rho_x = \frac{p_x}{R_w \Theta_x}$$

where R_w is the gas constant of humid gas.

3.29 volume flowrate at a section x , q_{Vx} : Mass flowrate at the specified airway cross-section divided by the corresponding mean value, over time, of the average density at that section.

$$q_{Vx} = \frac{q_m}{\rho_x}$$

3.30 average velocity at a section x, v_{mx} : Volume flowrate at the specified airway cross-section divided by the cross-sectional area A_x .

$$v_{mx} = \frac{q_{Vx}}{A_x}$$

NOTE 4 This is the mean value, over time, of the average component of the gas velocity normal to that section.

3.31 conventional dynamic pressure at a section x, p_{dx} : Dynamic pressure calculated from the average velocity and the average density at the specified airway cross-section.

$$p_{dx} = \rho_x \frac{v_{mx}^2}{2} = \frac{1}{2\rho_x} \left(\frac{q_m}{A_x} \right)^2$$

NOTE 5 The conventional dynamic pressure will be less than the average of the dynamic pressures across the section.

3.32 Mach number at a section x, Ma_x : Average gas velocity divided by the velocity of sound at the specified airway cross-section.

$$Ma_x = v_{mx} / \sqrt{\kappa R_w \Theta_x}$$

3.33 average stagnation pressure at a section x, p_{sgx} : Sum of the conventional dynamic pressure p_{dx} corrected by the Mach factor coefficient F_{Mx} at the section and the average absolute pressure p_x :

$$p_{sgx} = p_x + p_{dx} F_{Mx}$$

NOTE 6 The average stagnation pressure may be calculated by the expression

$$p_{sgx} = p_x \left(1 + \frac{\kappa - 1}{2} Ma_x^2 \right)^{\frac{\kappa}{\kappa - 1}}$$

ITEH STANDARD PREVIEW
(standards.iteh.ai)

3.34 gauge stagnation pressure at a section x, p_{esgx} : Difference between the average stagnation pressure, p_{sgx} , at a section and the atmospheric pressure, p_a .

$$p_{esgx} = p_{sgx} - p_a$$

ISO 5801:1997
<https://standards.iteh.ai/catalog/standards/sist/995a0191-cdeb-4122-ba51-797e3b3a44b6/iso-5801-1997>

3.35 inlet stagnation temperature, Θ_{sg1} : Absolute temperature in the test enclosure near the fan inlet at a section where the gas velocity is less than 25 m·s⁻¹.

In this case the stagnation temperature may be considered as equal to the ambient temperature Θ_a .

$$\Theta_{sg1} = \Theta_a = t_a + 273,15$$

3.36 stagnation density, ρ_{sg1} : Density calculated from the inlet stagnation pressure p_{sg1} and the inlet stagnation temperature Θ_{sg1} :

$$\rho_{sg1} = \frac{p_{sg1}}{R_w \Theta_{sg1}}$$

3.37 inlet stagnation volume flowrate, q_{Vsg1} : Mass flowrate divided by the inlet stagnation density.

$$q_{Vsg1} = \frac{q_m}{\rho_{sg1}}$$

3.38 fan pressure, p_F : Difference between the stagnation pressure at the fan outlet and the stagnation pressure at the fan inlet.

$$p_F = p_{sg2} - p_{sg1}$$

When the Mach number is less than 0,15,

$$p_F = p_{tF} = p_{t2} - p_{t1}$$

NOTE 7 Fan pressure should be referred to the installation type A, B, C or D.