

ISO/TC 86/SC 1

Secretariat: ANSI

Voting begins on:
2012-08-03

Voting terminates on:
2012-10-03

Refrigerating systems and heat pumps — Safety and environmental requirements —

Part 3: Installation site

*Systèmes de réfrigération et pompes à chaleur — Exigences de
sécurité et d'environnement —*

Partie 3: Site d'installation

RECIPIENTS OF THIS DRAFT ARE INVITED TO SUBMIT, WITH THEIR COMMENTS, NOTIFICATION OF ANY RELEVANT PATENT RIGHTS OF WHICH THEY ARE AWARE AND TO PROVIDE SUPPORTING DOCUMENTATION.

IN ADDITION TO THEIR EVALUATION AS BEING ACCEPTABLE FOR INDUSTRIAL, TECHNOLOGICAL, COMMERCIAL AND USER PURPOSES, DRAFT INTERNATIONAL STANDARDS MAY ON OCCASION HAVE TO BE CONSIDERED IN THE LIGHT OF THEIR POTENTIAL TO BECOME STANDARDS TO WHICH REFERENCE MAY BE MADE IN NATIONAL REGULATIONS.



Reference number
ISO/FDIS 5149-3:2012(E)

© ISO 2012

iTeh STANDARD PREVIEW
(standards.iteh.ai)
Full standard:
<https://standards.iteh.ai/catalog/standards/sist/14d972a6-a7bc-47fc-a098-0ea262a4c905/iso-5149-3-2014>

Copyright notice

This ISO document is a Draft International Standard and is copyright-protected by ISO. Except as permitted under the applicable laws of the user's country, neither this ISO draft nor any extract from it may be reproduced, stored in a retrieval system or transmitted in any form or by any means, electronic, photocopying, recording or otherwise, without prior written permission being secured.

Requests for permission to reproduce should be addressed to either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Case postale 56 • CH-1211 Geneva 20
Tel. + 41 22 749 01 11
Fax + 41 22 749 09 47
E-mail copyright@iso.org
Web www.iso.org

Reproduction may be subject to royalty payments or a licensing agreement.

Violators may be prosecuted.

Contents

Page

Foreword	v
1 Scope	1
2 Normative references	1
3 Terms and definitions	1
4 Location of refrigerating equipment	2
4.1 General	2
4.2 Refrigerating equipment located in the open air	2
4.3 Refrigerating equipment located in a machinery room	2
4.4 Refrigerating equipment located in the occupied space	2
4.5 Refrigerating equipment located in unoccupied areas not designated a machinery room	2
4.6 Refrigerating equipment located in a ventilated enclosure within an occupied space	2
4.7 Piping duct or shaft	3
5 Machinery rooms	3
5.1 Occupancy of machinery rooms and special machinery rooms	3
5.2 Venting from or through the machinery room	3
5.3 Combustion equipment and air compressors	3
5.4 Open flame	3
5.5 Storage	3
5.6 Remote emergency switch	4
5.7 Exterior openings of the machinery room	4
5.8 Piping and ducting	4
5.9 Normal lighting	4
5.10 Emergency lighting	4
5.11 Dimensions and accessibility	4
5.12 Doors, walls and ducts	4
5.13 Ventilation	5
5.14 Machinery rooms for flammable refrigerants (groups A2, B2, B3 and A3)	6
6 Requirements for alternative provisions	7
6.1 General	7
6.2 Occupied space	7
6.3 Ventilation	8
6.4 Safety shut off valves	9
7 Electrical installations	10
7.1 General requirements	10
7.2 Main power supply	10
7.3 Electrical equipment in machinery rooms in which a refrigerating system contains class 2L flammability refrigerants	10
8 Safety alarms	10
8.1 General	10
8.2 Alarm system power	10
8.3 Alarm system warning	10
8.4 Additional alarm system requirements for ammonia systems with charges above 4 500 kg	11
9 Detectors	11
9.1 General	11
9.2 Location of detectors	11
9.3 Function of the detector	11
9.4 Type and performance of a detector	11
9.5 Installation	12
10 Instruction manuals, notices and inspections	12
10.1 Instruction manual	12

10.2	Warning notice.....	12
10.3	Visual inspection of site.....	13
10.4	Maintenance of the site.....	13
11	Heat sources and temporary high temperatures located at the site	13
	Bibliography	14

iTeh STANDARD PREVIEW
(standards.iteh.ai)
Full standard:
<https://standards.iteh.ai/catalog/standards/sist/14d972a6-a7bc-47fc-a098-0ea262a4c905/iso-5149-3-2014>

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO 5149-3 was prepared by Technical Committee ISO/TC 86, *Refrigeration and air-conditioning*, Subcommittee SC 1, *Safety and environmental requirements for refrigerating systems*.

This first edition of ISO 5149-3, together with ISO 5149-1, ISO 5149-2 and ISO 5149-4, cancels and replaces ISO 5149:1993, which has been technically revised.

ISO 5149 consists of the following parts, under the general title *Refrigerating systems and heat pumps — Safety and environmental requirements*:

- *Part 1: Definitions, classification and selection criteria*
- *Part 2: Design, construction, testing, marking and documentation*
- *Part 3: Installation site*
- *Part 4: Operation, maintenance, repair and recovery*

iTeh STANDARD PREVIEW
(standards.iteh.ai)

Full standard:
<https://standards.iteh.ai/catalog/standards/sist/14d972a6-a7bc-47fc-a098-0ea262a4c905/iso-5149-3-2014>

Refrigerating systems and heat pumps — Safety and environmental requirements —

Part 3: Installation site

1 Scope

This part of ISO 5149 is applicable to the installation site (plant space and services). It specifies requirements on the site for safety, which may be needed because of, but not directly connected with, the refrigerating system and its ancillary components.

This part of ISO 5149 is applicable to new refrigerating systems, extensions or modifications of existing systems, and for used systems being transferred to and operated on another site. Deviations are permissible only if equivalent protection is ensured.

This part of ISO 5149 also applies in the case of the conversion of a system for another refrigerant.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 5149-1:—¹⁾, *Refrigerating systems and heat pumps — Safety and environmental requirements — Part 1: Definitions, classification and selection criteria*

ISO 5149-2:—²⁾, *Refrigerating systems and heat pumps — Safety and environmental requirements — Part 2: Design, construction, testing, marking and documentation*

ISO 13850, *Safety of machinery — Emergency stop — Principles for design*

IEC 60204-1, *Safety of machinery — Electrical equipment of machines — General requirements*

IEC 60364-1, *Low-voltage electrical installations — Part 1: Fundamental principles, assessment of general characteristics, definitions*

IEC 60364-5, *Electrical installations of buildings — Part 5: Selection and erection of electrical equipment*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 5149-1 apply.

1) To be published.

2) To be published.

4 Location of refrigerating equipment

4.1 General

Refrigerating equipment may be sited outside the building in the open air or in a designated machinery room or in occupied areas or in unoccupied areas not designated as a machinery room.

NOTE The refrigerating equipment may be contained in a ventilated enclosure provided by the manufacturer. Requirements for this enclosure are given in ISO 5149-2:—, 5.2.17.

4.2 Refrigerating equipment located in the open air

Refrigerating systems sited in the open air shall be positioned to avoid refrigerant leaking into the building or endangering people. If sited on the roof the refrigerant shall not be able to flow across the roof into any ventilation fresh air opening, doorway, trap door or similar opening in the event of a leak. Where a shelter is provided for refrigerating equipment sited in the open air, it shall have natural or forced ventilation.

A room where at least one of the longest walls is open to the outside air by means of louvres with 75 % free area and covering at least 80 % of the wall area (or the equivalent if more than one wall is to outside) is considered as being in the open air.

4.3 Refrigerating equipment located in a machinery room

When a machinery room is chosen for the location of the refrigerating equipment, it shall meet the requirements specified in 5.1 to 5.14. Where the charge of a refrigerant is above the practical limits specified in ISO 5149-1:— the refrigerating system shall be located in a special machinery room unless the ignition sources in the machinery room meet the requirements of 5.3, 5.4 and 5.14.4.

NOTE 1 Additional requirements may be needed for refrigerating systems containing ammonia or other B2, B3, A2 and A3 refrigerants as specified in 5.12.

NOTE 2 Where housing around refrigerating equipment is sufficiently large for people to enter, the housing should be considered as a machinery room and requirements for such rooms apply.

4.4 Refrigerating equipment located in the occupied space

The requirements shall be as specified in ISO 5149-1:—, Annex A.

4.5 Refrigerating equipment located in unoccupied areas not designated a machinery room

If this area is sealed from any occupied area, the requirements shall be as those for a machinery room. If the area cannot be sealed from any occupied space then the refrigerating machinery shall be considered as located in the human occupied space and requirements for such spaces shall apply.

4.6 Refrigerating equipment located in a ventilated enclosure within an occupied space

The ventilated enclosure containing the refrigerating system shall have a ventilation duct as specified by the manufacturer. The duct shall be no greater in length and have no more bends than the maximum number specified by the manufacturer. The room into which the ventilated enclosure is installed shall be at least 10 times the volume of the enclosure and shall have sufficient make up air to replace any exhausted air. The ventilation from the enclosure shall be to outside air or to a room having a minimum volume specified in ISO 5149-1 for an occupied space.

4.7 Piping duct or shaft

Where hand operated shut-off devices are mounted in a piping duct or shaft designed for human entry, the duct or shaft shall have more than one escape exit. The duct shall have at least 1,2 m of ceiling height.

5 Machinery rooms

5.1 Occupancy of machinery rooms and special machinery rooms

Machinery rooms should not be used as occupied spaces. The building owner or user shall ensure that access is permitted only by instructed personnel doing the necessary maintenance to the machinery room or general plant. If machinery rooms are occupied for significant periods, e.g. used as a building maintenance workspace, they shall be considered as occupied spaces under occupancy category "C" "Authorized Occupancy" given in ISO 5149-1:—.

A special machinery room shall not be used as an occupied space.

NOTE In accordance with ISO 5149-4, when occupied for maintenance or repair, a duly authorized person, familiar with the use of the emergency protective equipment and emergency procedures, should be available near to the machinery room during such occupation in case of an emergency.

5.2 Venting from or through the machinery room

Refrigerant shall be prevented from entering neighbouring rooms, staircases, courts, gangways or building draining systems and the escaping gas shall be vented outdoors.

There shall be no airflow to an occupied space through a machinery room unless the air is ducted and sealed to prevent any refrigerant leakage from entering the air stream.

5.3 Combustion equipment and air compressors

Where combustion equipment is located in a machinery room containing refrigerating equipment, the combustion air supply for combustion engines, boilers or the supply air for air compressors shall be drawn from a place where there is no refrigerant gas. If such equipment is installed in a machinery room, the combustion air for combustion engines or the supply air for air compressors shall be ducted from outside in such a manner as to prevent any refrigerant leakage from entering the combustion chamber.

5.4 Open flame

Open (naked) flames shall not be permitted in machinery rooms or special machinery rooms, except for welding, brazing or similar activity and then only provided the refrigerant concentration is monitored and adequate ventilation is ensured. Such open flames shall not be left unattended.

NOTE When the refrigerant in the refrigerating machinery is R-744, the use of an open flame may be permitted.

The ventilation rate for welding and brazing shall be adequate considering the combustion (products of combustion) of any refrigerant contained in the room.

5.5 Storage

Machinery rooms shall not be used for storage with the exception of tools, spare parts and compressor oil for the installed equipment. Any refrigerants, flammable or toxic materials shall be stored as required by national regulations.

5.6 Remote emergency switch

A remote switch for stopping the refrigerating system shall be provided outside the room, near to the machinery room. A similar acting switch shall be located at a suitable location inside the room. The switches shall meet the requirements for emergency switches in accordance with ISO 13850 and IEC 60204-1.

5.7 Exterior openings of the machinery room

Exterior openings shall not be situated within 2 m of building emergency exit staircases or other building openings, e.g. windows, doors, ventilation inlets, etc.

5.8 Piping and ducting

All piping and ventilation ducting that passes through walls, ceiling and floors of machinery rooms shall be sealed where it passes through the walls, ceiling or floors. The sealing shall have at least equivalent fire resisting properties to the walls, ceiling or floor.

NOTE 1 Discharge pipes from relief devices, safety valves and fusible plugs may diffuse the charge into the air by adequate means but away from any air intake to the building or discharge into an adequate quantity of a suitable absorbing material.

NOTE 2 Relief devices for refrigerants in group A1 may discharge into the machinery room provided the system charge is less than the limits set in Annex A of ISO 5149-1:— . Such discharges of refrigerant should take place so that persons and property are not endangered.

5.9 Normal lighting

Fixed lighting shall be selected and positioned in spaces containing refrigerating equipment to provide adequate illumination for safe operation. The illumination level and location shall be as required by national regulations. Filament light bulbs shall be protected by "splash safe" covers (IPX 4) in machinery rooms containing ammonia refrigerating systems.

5.10 Emergency lighting

A fixed or portable emergency lighting system shall be provided, adequate to allow operation of controls and evacuation of personnel, when normal lighting fails.

5.11 Dimensions and accessibility

The dimensions of the machinery room shall allow easy installation and sufficient room for service, maintenance, operation, repair and disassembly of the refrigerating equipment, including sufficient space for persons wearing personal protection equipment.

If necessary, catwalks and fixed ladders shall be provided in order to avoid standing or walking on piping, fittings, their supports and supporting structures and on components during the operation, maintenance, inspection and repair of the refrigerating system.

There shall be clear headroom of at least 2 m below equipment situated over gangways and permanent work places.

NOTE Headroom is defined by 2 m above the walking surface.

5.12 Doors, walls and ducts

5.12.1 Doors and openings

Machinery rooms shall have doors opening outward and sufficient in number to ensure persons can escape in an emergency.