



SLOVENSKI STANDARD SIST EN IEC 60120:2020

01-december-2020

Nadomešča:
SIST HD 474 S1:1998

Betiči in ponvice za člene izolatorskih verig - Dimenzije (IEC 60120:2020)

Ball and socket couplings of string insulator units - Dimensions (IEC 60120:2020)

Maße von Klöppel-Pfannen-Verbindungen für Kettenisolatoren PREVERI NASLOV

Assemblages à rotule des éléments de chaînes d'isolateurs - Dimensions (IEC 60120:2020)

iTeh STANDARD PREVIEW
(standards.iteh.ai)

Ta slovenski standard je istoveten z: EN IEC 60120:2020

SIST EN IEC 60120:2020
<https://standards.iteh.ai/catalog/standards/sist/c313c71c-6592-43d-8563-978d39e187a0/sist-en-iec-60120-2020>

ICS:

29.080.10	Izolatorji	Insulators
-----------	------------	------------

SIST EN IEC 60120:2020

en,fr,de

iTeh STANDARD PREVIEW **(standards.iteh.ai)**

SIST EN IEC 60120:2020

<https://standards.iteh.ai/catalog/standards/sist/e315c71e-0352-4f3d-8563-978d39e187a0/sist-en-iec-60120-2020>

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN IEC 60120

September 2020

ICS 29.080.10; 29.240.20

Supersedes HD 474 S1:1986 and all of its amendments
and corrigenda (if any)

English Version

**Ball and socket couplings of string insulator units - Dimensions
(IEC 60120:2020)**

Assemblages à rotule des éléments de chaînes d'isolateurs
- Dimensions
(IEC 60120:2020)

To be completed
(IEC 60120:2020)

This European Standard was approved by CENELEC on 2020-08-26. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

EN IEC 60120:2020 (E)**European foreword**

The text of document 36/486/FDIS, future edition 4 of IEC 60120, prepared by IEC/TC 36 "Insulators" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 60120:2020.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2021-05-26
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2023-08-26

This document supersedes HD 474 S1:1986 and all of its amendments and corrigenda (if any).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

iTeh STANDARD PREVIEW Endorsement notice (standards.iteh.ai)

The text of the International Standard IEC 60120:2020 was approved by CENELEC as a European Standard without any modification.

<https://standards.iteh.ai/catalog/standards/sist/e315c71e-0352-4f3d-8563-978d39e187a0/sist-en-iec-60120-2020>

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 60305	NOTE	Harmonized as EN 60305
IEC 60383-1	NOTE	Harmonized as EN 60383-1
IEC 60433	NOTE	Harmonized as EN 60433
IEC 61325	NOTE	Harmonized as EN 61325

Annex ZA

(normative)

Normative references to international publications with their corresponding European publications

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 Where an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60050-471	2007	International Electrotechnical Vocabulary - Part 471: Insulators	-	-
IEC 60372	-	Locking devices for ball and socket couplings of string insulator units Dimensions and tests	-	-

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN IEC 60120:2020
<https://standards.iteh.ai/catalog/standards/sist/e315c71e-0352-4f3d-8563-978d39e187a0/sist-en-iec-60120-2020>

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN IEC 60120:2020

<https://standards.iteh.ai/catalog/standards/sist/e315c71e-0352-4f3d-8563-978d39e187a0/sist-en-iec-60120-2020>



IEC 60120

Edition 4.0 2020-07

INTERNATIONAL STANDARD

NORME INTERNATIONALE

Ball and socket couplings of string insulator units – Dimensions

Assemblages à rotule des éléments de chaînes d'isolateurs – Dimensions

[SIST EN IEC 60120:2020](https://standards.iteh.ai/catalog/standards/sist/e315c71e-0352-4f3d-8563-978d39e187a0/sist-en-iec-60120-2020)

<https://standards.iteh.ai/catalog/standards/sist/e315c71e-0352-4f3d-8563-978d39e187a0/sist-en-iec-60120-2020>

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 29.080.10; 29.240.20

ISBN 978-2-8322-8475-9

Warning! Make sure that you obtained this publication from an authorized distributor.

Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.

CONTENTS

FOREWORD	4
1 Scope	6
2 Normative references	6
3 Terms and definitions	6
4 Designated size of coupling	7
5 Pin ball	7
6 Socket	7
7 Hook-on "GO" gauge	7
8 Lower part of the insulator	7
9 Locking device	7
10 Dimensions of the pin ball	8
11 Dimensions of the socket end	9
12 Dimensions of the hook-on "GO" gauge	10
13 Dimensions of twin-balled pins	13
14 Dimensions of the hole for the split-pin	13
15 Dimensions of the hole for the W-clip	15
Annex A (informative) Extreme positions of the pin ball in the socket	16
Annex B (normative) Recommended gauges	18
Annex C (informative) Dimensions obtained by calculation	35
Bibliography	37
Figure 1 – Schematic of the pin ball	8
Figure 2 – Schematic of the socket end	9
Figure 3 – Schematic of the hook-on "GO" gauge	10
Figure 4 – Schematic of twin-balled pins	13
Figure 5 – Schematic of the hole for the split-pin	14
Figure 6 – Schematic of the hole for the W-clip	15
Figure A.1 – Sliding position of the pin ball (socket end)	16
Figure A.2 – Over-tilting position of the pin ball in the socket end	17
Figure B.1 – Schematic of ball part for pin ball	19
Figure B.2 – Schematic of inspecting part for cap	19
Figure B.3 – Schematic of pin "GO" gauge for ball height, shank diameter and shank length	20
Figure B.4 – Schematic of pin "GO" gauge for ball diameter	22
Figure B.5 – Schematic of pin "NOT GO" gauge for ball height	23
Figure B.6 – Schematic of pin "NOT GO" gauge for ball diameter	25
Figure B.7 – Schematic of pin "NOT GO" gauge for shank diameter	26
Figure B.8 – Schematic of socket "GO" gauge for entry height, entry width and neck width	27
Figure B.9 – Schematic of socket "GO" gauge for internal height and internal diameter	29
Figure B.10 – Schematic of socket "NOT GO" gauge for entry height	32
Figure B.11 – Schematic of socket "NOT GO" gauge for neck width	34

Figure C.1 – Schematic of clearance between the pin ball and the socket end	35
Figure C.2 – Effectiveness of locking the pin ball	36
Table 1 – Dimensions of the pin ball	8
Table 2 – Dimensions of the socket end	9
Table 3 – Dimensions of the hook-on "GO" gauge	11
Table 4 – Dimensions of twin-balled pins	13
Table 5 – Dimensions of the hole for the split-pin	14
Table 6 – Dimensions of the hole for the W-clip	15
Table A.1 – Allowed deviation angle of pin	16
Table A.2 – Allowed deviation angle of pin	17
Table B.1 – Dimensions of pin "GO" gauge for ball height, shank diameter and shank length	21
Table B.2 – Dimensions of pin "GO" gauge for ball diameter	23
Table B.3 – Dimensions of pin "NOT GO" gauge for ball height	24
Table B.4 – Dimensions of pin "NOT GO" gauge for ball diameter	25
Table B.5 – Dimensions of pin "NOT GO" gauge for shank diameter	26
Table B.6 – Dimensions of socket "GO" gauge for entry height, entry width and neck width	27
Table B.7 – Dimensions of socket "GO" gauge for internal height and internal diameter	30
Table B.8 – Dimensions of socket "NOT GO" gauge for entry height	32
Table B.9 – Dimensions of socket "NOT GO" gauge for neck width	34
Table C.1 – Clearance between the pin ball and the socket end	35
Table C.2 – Effectiveness of locking the pin ball	36

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**BALL AND SOCKET COUPLINGS OF STRING
INSULATOR UNITS – DIMENSIONS**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60120 has been prepared by IEC technical committee 36: Insulators.

This fourth edition cancels and replaces the third edition published in 1984. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) Two new designated size of couplings, 36 and 40 were introduced;
- b) According to the results of the questionnaire(36/424/Q), the relevant content of the 28B W-clip was deleted;
- c) The Q_{min} column in Table C.1 was deleted;
- d) Annex A is informative, Annex B is normative, Annex C is informative.

The text of this International Standard is based on the following documents:

FDIS	Report on voting
36/486/FDIS	36/492/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

iTeh STANDARD PREVIEW (standards.iteh.ai)

[SIST EN IEC 60120:2020](https://standards.iteh.ai/catalog/standards/sist/e315c71e-0352-4f3d-8563-978d39e187a0/sist-en-iec-60120-2020)

<https://standards.iteh.ai/catalog/standards/sist/e315c71e-0352-4f3d-8563-978d39e187a0/sist-en-iec-60120-2020>

BALL AND SOCKET COUPLINGS OF STRING INSULATOR UNITS – DIMENSIONS

1 Scope

The object of this international standard is to define the dimensions of a series of standard ball and socket couplings using the standard locking devices (see IEC 60372) in order to permit the assembly of insulators or metal fittings supplied by different manufacturers.

This document applies to string insulator units of the cap and pin and long rod types and their associated metal fittings.

For the pin ball and the socket, dimensions apply to the finished product after any surface treatment.

Extreme positions of the pin ball in the socket are given in Annex A.

Typical examples of gauges for checking the dimensions of pin balls and sockets are given in Annex B.

NOTE Only the dimensions necessary for assembly are dealt with in this standard. Properties of material and working loads are not specified. The co-ordination of dimensions with strength classes is specified in IEC 60305 and IEC 60433.

2 Normative references

SIST EN IEC 60120:2020

<https://standards.iteh.ai/catalog/standards/sist/e315c71e-0352-4f3d-8563-6f8d3016740/sist-en-iec-60120-2020>

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050-471:2007, *International Electrotechnical Vocabulary (IEV) – Part 471: Insulators*

IEC 60372, *Locking devices for ball and socket couplings of string insulator units – Dimensions and tests*

3 Terms and definitions

For the purposes of this document, the terms and definitions of IEC 60050-471, some of which are reproduced below for ease of reference, apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

3.1

ball and socket coupling

coupling consisting of a ball, a socket and a locking device, and providing flexibility

[SOURCE: IEC 60050-471:2007, 471-03-11]

3.2**string insulator unit**

cap and pin insulator or long rod insulator of which end fitting are suitable for flexible attachment to other similar insulator units or to connecting accessories

[SOURCE: IEC 60050-471:2007, 471-03-08]

4 Designated size of coupling

This document includes eight standard ball and socket couplings designated by the nominal pin diameters in millimetres. Each designated size of coupling is defined by the dimensions of the pin ball, of the socket, of the hook-on "GO" gauge, of the lower part of the insulator and of the corresponding locking device.

NOTE Dimensions of twin-balled pins for coupling of two sockets are stated in Clause 13. Dimensions of the hole for the locking devices are stated in Clause 14 and Clause 15.

5 Pin ball

The pin ball shall conform to the dimensions specified in Clause 10. The main dimensions governing the shape of the pin ball are h_1 , d_2 , r_1 and r_2 . Dimension r_3 is given for guidance because its accurate value may be obtained only by the drawing. In addition, the shank diameter d_1 , must not exceed the specified values within a length equal to H_3 of the corresponding worn hook-on "GO" gauge (see Clause 12).

6 Socket

The socket interior shall conform to the dimensions specified in Clause 11, which also specifies the thickness of the locking device.

The 16 mm designated size of coupling according to Clause 11 includes two alternative sockets. There is only one type of pin ball fit for it, but the corresponding locking device should be used. That is, the 16A socket should be matched with the 16A locking device, the 16B socket should be matched with the 16B locking device.

NOTE Sockets according to the clause mentioned are shown with flat bottoms. Sockets with rounded bottoms with radii of curvature not less than the dimensions r_2 of the pin balls can also be used. In this case, the dimensions R_5 have to be correspondingly decreased.

7 Hook-on "GO" gauge

The external dimensions of the socket have not been laid down. However, the socket shall permit acceptance of the hook-on "GO" gauge according to Clause 12.

8 Lower part of the insulator

The shape of the lower part of the insulator shall be such that assembly with the socket of maximum external dimensions according to Clause 7 will always be possible.

9 Locking device

The locking device, i. e. a split-pin or W-clip, shall be designed for locking the minimum-size pin ball in the maximum size socket. This requirement is fulfilled if the locking devices standardized in IEC 60372 are used.