
Električne naprave za shranjevanje energije (EES) - 1. del: Slovar (IEC 62933-1:2024)

Electrical energy storage (EES) systems - Part 1: Vocabulary (IEC 62933-1:2024)

Elektrische Energiespeichersysteme (EES-Systeme) - Teil 1: Terminologie (IEC 62933-1:2024)

Systèmes de stockage de l'énergie électrique (EES) - Partie 1: Vocabulaire (IEC 62933-1:2024)

Ta slovenski standard je istoveten z: EN IEC 62933-1:2024

SIST EN IEC 62933-1:2024

<https://standards.iteh.ai/catalog/standards/sist/989c5c0a-0e54-40eb-8328-afec170db98c/sist-en-iec-62933-1-2024>

ICS:

01.040.27	Prenos energije in toplote (Slovarji)	Energy and heat transfer engineering (Vocabularies)
27.010	Prenos energije in toplote na splošno	Energy and heat transfer engineering in general

SIST EN IEC 62933-1:2024**en**

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN IEC 62933-1

June 2024

ICS 01.040.17

Supersedes EN IEC 62933-1:2018

English Version

Electrical energy storage (EES) systems - Part 1: Vocabulary
(IEC 62933-1:2024)

Systèmes de stockage de l'énergie électrique (EES) - Partie
1 : Vocabulaire
(IEC 62933-1:2024)

Elektrische Energiespeichersysteme (EES-Systeme) - Teil
1: Terminologie
(IEC 62933-1:2024)

This European Standard was approved by CENELEC on 2024-06-19. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.

iTeh Standards
Document Preview

SIST EN IEC 62933-1:2024

<https://standards.iteh.ai/catalog/standards/sist/989c5c0a-0e54-40eb-8328-afec170db98c/sist-en-iec-62933-1-2024>



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

EN IEC 62933-1:2024 (E)**European foreword**

The text of document 120/358/FDIS, future edition 2 of IEC 62933-1, prepared by IEC/TC 120 "Electrical Energy Storage (EES) systems" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 62933-1:2024.

The following dates are fixed:

- latest date by which the document has to be implemented at national (dop) 2025-03-19 level by publication of an identical national standard or by endorsement
- latest date by which the national standards conflicting with the (dow) 2027-06-19 document have to be withdrawn

This document supersedes EN IEC 62933-1:2018 and all of its amendments and corrigenda (if any).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

Any feedback and questions on this document should be directed to the users' national committee. A complete listing of these bodies can be found on the CENELEC website.

Endorsement notice

The text of the International Standard IEC 62933-1:2024 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standard indicated:

IEC 60027 series	NOTE	Approved as EN 60027 series
IEC 61165:2006	NOTE	Approved as EN 61165:2006 (not modified)
IEC 61427-2:2015	NOTE	Approved as EN 61427-2:2015 (not modified)
IEC 61850-4:2011	NOTE	Approved as EN 61850-4:2011 (not modified)
IEC 61850-4:2011/A1:2020	NOTE	Approved as EN 61850-4:2011/A1:2020 (not modified)
IEC 61987-1:2006	NOTE	Approved as EN 61987-1:2007 (not modified)
IEC 62381:2012	NOTE	Approved as EN 62381:2012 (not modified)
IEC 62443-3-3:2013	NOTE	Approved as EN IEC 62443-3-3:2019 (not modified)
IEC 62477-1:2012	NOTE	Approved as EN 62477-1:2012 (not modified) +A11:2014
IEC 62668-1:2019	NOTE	Approved as EN IEC 62668-1:2019 (not modified)
IEC 62680 series	NOTE	Approved as EN IEC 62680 series
IEC 62928:2017	NOTE	Approved as EN IEC 62928:2018 (not modified)
IEC 62932-1:2020	NOTE	Approved as EN IEC 62932-1:2020 (not modified)
IEC 62934:2021	NOTE	Approved as EN IEC 62934:2021 (not modified)
ISO 14050:2020	NOTE	Approved as EN ISO 14050:2020 (not modified)



IEC 62933-1

Edition 2.0 2024-05

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Electrical energy storage (EES) systems –
Part 1: Vocabulary**

**Systèmes de stockage de l'énergie électrique (EES) –
Partie 1 : Vocabulaire**

iTeh Standards
<https://standards.iteh.ai/>
Document Preview

SIST EN IEC 62933-1:2024

<https://standards.iteh.ai/catalog/standards/sist/989c5c0a-0e54-40eb-8328-afec170db98c/sist-en-iec-62933-1-2024>

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 01.040.17

ISBN 978-2-8322-8797-2

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD.....	3
INTRODUCTION.....	5
1 Scope.....	6
2 Normative references	6
3 Terms and definitions for EES systems classification.....	6
3.1 Fundamental concepts for EES systems classification	6
3.2 EES systems classification	7
3.3 EES systems long-duration application	9
3.4 EES systems short-duration application	10
3.5 EES systems hybrid and emergency application	12
4 Terms and definitions for EES systems specification	12
4.1 Fundamental concepts for EES systems specification	12
4.2 EES system duty cycles	15
4.3 EES system primary POC	17
4.4 EES system auxiliary POC	24
4.5 EES system service life	25
4.6 EES system energy efficiency	27
4.7 EES system step response performances	29
5 Terms and definitions for EES systems planning and installation	32
5.1 Fundamental concepts for EES systems planning and installation	32
5.2 EES system primary subsystem	33
5.3 EES system auxiliary subsystem.....	34
5.4 EES system control subsystem	35
6 Terms and definitions for EES systems operation	36
6.1 EES system operating state	36
6.2 EES system operating signals.....	37
6.3 EES system operating procedure	40
6.4 EES system operating mode	40
7 Terms and definitions for EES systems' environmental and safety issues	41
7.1 EES system environmental issues	41
7.2 EES system safety.....	42
Annex A (informative) Index	45
A.1 Terms index.....	45
A.2 Abbreviated terms index	45
Bibliography.....	51
Figure 1 – Illustrative example of EES system energy storage capacities relation	14
Figure 2 – Illustrative example of EES system charging-discharging cycle	16
Figure 3 – Illustrative example of EES system power capability chart.....	17
Figure 4 – Illustrative example of EES system response performances	30
Figure 5 – EES system architecture with one POC type	33
Figure 6 – EES system architecture with two POC types.....	34
Figure 7 – Illustrative example of EES system available energies relation.....	38
Table 1 – Illustrative example of EES system efficiency chart	27

INTERNATIONAL ELECTROTECHNICAL COMMISSION

ELECTRICAL ENERGY STORAGE (EES) SYSTEMS –**Part 1: Vocabulary****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 62933-1 has been prepared by IEC technical committee 120: Electrical Energy Storage (EES) systems. It is an International Standard.

This second edition cancels and replaces the first edition published in 2018. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) addition (with revision) of the entries developed during the edition 1 stability period and, therefore, included only in other IEC 62933 parts;
- b) addition of the entries developed during the edition 1 stability period and published in this document for the first time;
- c) complete revision of the entries already present in edition 1.

The text of this International Standard is based on the following documents:

Draft	Report on voting
120/358/FDIS	120/367/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all parts in the IEC 62933 series, published under the general title *Electrical energy storage (EES) systems*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

iTeh Standards
(<https://standards.iteh.ai>)

IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

[SIST EN IEC 62933-1:2024](https://standards.iteh.ai/catalog/standards/sist/989c5c0a-0e54-40eb-8328-afec170db98c/sist-en-iec-62933-1-2024)

<https://standards.iteh.ai/catalog/standards/sist/989c5c0a-0e54-40eb-8328-afec170db98c/sist-en-iec-62933-1-2024>

INTRODUCTION

The purpose of this terminology document is to provide terms and definitions for all the publications under the responsibility of TC 120, that standardize electrical energy storage systems (EES systems) including unit parameters, test methods, planning, installation, operation, safety and environmental issues. An EES system includes any type of grid-connected energy storages which can both store electrical energy and provide electrical energy (from electricity to electricity).

All TC 120 normative documents are subject to revision; this part of IEC 62933 will be revised together with other TC 120 publications in order to avoid mismatches.

From the technical point of view, an EES system can be a complex multi-stage system with several possible energy conversions. Each stage is made by well standardized components (e.g. transformers, power conversion systems) or innovative components (e.g. new types of batteries). Several IEC product standards give definitions necessary for the understanding of certain terms used for these components. The International Electrotechnical Vocabulary (IEV, <http://www.electropedia.org>), the IEC Glossary (<http://std.iec.ch/glossary>) and the ISO Online Browsing Platform (OBP, <http://www.iso.org/obp>) allow online access to this information. This document completes the need for precise terminology by giving definitions necessary at the system level.

Without a strong standardization of EES system terminology, focal terms can have a different meaning in EES systems related to different storage technologies. This aspect is critical also from the market point of view. It impacts economics and this can become a barrier for tender processes. The correct comparison among different options is fundamental, therefore basic terms and definitions impact economic decisions.

Terms and definitions have been harmonized with the IEV, the OBP, the IEC Glossary and relevant IEC documents as far as possible. Definitions not included in this terminology document can be found elsewhere in other IEC documents.

The use of abbreviated terms has been optimized: on the one hand to avoid tedious repetition and on the other hand to avoid confusion. A minimum set of abbreviated terms was identified and used in the definitions, the other terms are written out in full spelling when needed. The widely accepted abbreviated terms are:

EESS – EES system – Electrical energy storage system

EES – Electrical energy storage

POC – Point of connection

In order to facilitate document usage, Clause A.1 offers a term index and Clause A.2 offers an abbreviated term index.

ELECTRICAL ENERGY STORAGE (EES) SYSTEMS –

Part 1: Vocabulary

1 Scope

This part of IEC 62933 defines terms applicable to electrical energy storage (EES) systems including terms necessary for the definition of unit parameters, test methods, planning, installation, operation, environmental and safety issues.

This terminology document is applicable to grid-connected systems able to extract electrical energy from an electric power system, store energy internally, and provide electrical energy to an electric power system. The step for charging and discharging an EES system can comprise an energy conversion.

2 Normative references

There are no normative references in this document.

3 Terms and definitions for EES systems classification

3.1 Fundamental concepts for EES systems classification

3.1.1

electrical energy storage

EES

electrical *installation* (IEV 826-10-01) able to absorb electrical energy, to store energy for a certain duration and to provide electrical energy

EXAMPLE An installation that absorbs electrical energy to produce hydrogen by electrolysis, stores the hydrogen, and uses that gas to produce electrical energy is an electrical energy storage.

Note 1 to entry: The term "electrical energy storage" can also be used to indicate the activity that an installation, described in the definition, carries out when performing its functions.

Note 2 to entry: The term "electrical energy storage" is generally not used to designate a grid-connected installation, for which *electrical energy storage system* (3.1.2) is the appropriate term.

Note 3 to entry: Energy conversion processes can be included during energy absorption, storage or release.

[SOURCE: IEC 60050-631:2023, 631-01-01, modified – minor editorial modifications in the definition and in the note 2.]

3.1.2

electrical energy storage system

EES system

EESS

grid-connected *installation* (IEV 826-10-01) with defined electrical boundaries, comprising at least one *electrical energy storage* (3.1.1), which extracts electrical energy from an *electric power system* (IEV 601-01-01), stores this energy internally in some manner and provides electrical energy to an *electric power system* (IEV 601-01-01), including grid-connection works and which can include civil engineering works, energy conversion equipment and related ancillary equipment

Note 1 to entry: The EES system is controlled and coordinated to provide services to the *electric power system* (IEV 601-01-01) operators or to the electric power system users.

Note 2 to entry: In some cases, an EES system can require an additional non-electrical energy source during its discharge, providing more energy to the electric power system than the energy it stored. A compressed air energy storage (CAES) is a typical example where additional thermal energy is required.

[SOURCE: IEC 60050-631:2023, 631-01-02, modified – minor editorial modifications in the definition and in the note 2.]

3.1.3

utility grid

part of an *electric power network* (IEV 601-01-02) that is operated by a *system operator* (IEV 617-02-09) within a defined area of responsibility

Note 1 to entry: A utility grid is normally used for electricity transfer from or to grid users or other grids. The grid users can be electricity producers or consumers. The area of responsibility is fixed by relevant legislation or regulation.

[SOURCE: IEC 60050-631:2023, 631-01-04 modified – system operator concept is added in the definition and minor editorial modifications in the note 1.]

3.1.4

grid-connected, adj

connected to an *electric power system* (IEV 601-01-01)

3.1.5

islanded grid

electric island

part of an *electric power system* (IEV 601-01-01) that is electrically disconnected from the remainder of the interconnected electric power system but remains energized from the local electric power sources

[SOURCE: IEC 60050-692:2017, 692-02-11, modified – the term “islanded grid” has been added and notes have been deleted.]

3.1.6

load profile

line graph illustrating the variation in loads over a specific time

3.1.7

allowed charging time

time period when an EES system is allowed to charge the accumulation subsystem in the peak shaving application

3.1.8

allowed discharging time

time period when an EES system is allowed to discharge the accumulation subsystem in the peak shaving application

3.2 EES systems classification

3.2.1

battery energy storage system

BESS

electrical energy storage system where the accumulation subsystem is a *battery storage subsystem* (5.2.4)

EXAMPLE *Flow battery energy system* (IEC 62932-1:2019, 2.17), *lithium ion battery* (IEV 482-05-07) energy storage system and lead acid battery energy storage system are different types of battery energy storage systems.

[SOURCE: IEC 60050-631:2023, 631-01-03, modified – battery storage subsystem concept inserted in the definition, notes deleted and the example added.]

3.2.2**capacitor energy storage system**

CESS

electrical energy storage system with the accumulation subsystem based on *capacitors* (IEV 151-13-28)

Note 1 to entry: Usually, capacitor energy storage systems are based on *supercapacitors* (IEV 114-03-03).

3.2.3**flywheel energy storage system**

FESS

electrical energy storage system with the accumulation subsystem based on flywheels

Note 1 to entry: A flywheel is a mechanical device where rotational kinetic energy is stored.

3.2.4**low voltage EESS**

EES system designed to be connected to a *low voltage* (IEV 601-01-26) primary POC

3.2.5**medium voltage EESS**

EES system designed to be connected to a *medium voltage* (IEV 601-01-28) primary POC

3.2.6**high voltage EESS**

EES system designed to be connected to a *high voltage* (IEV 601-01-27) primary POC

3.2.7**residential EESS**

EES system designed for *residential customer* (IEV 617-02-05), excluding professional users

Note 1 to entry: A residential EES system is normally compliant with the applicable standards for residential devices (e.g. electromagnetic compatibility).

Note 2 to entry: Professional users include commercial or industrial customers.

3.2.8**commercial EESS**

EES system designed for professional users

Note 1 to entry: A commercial and industrial EES system is normally compliant with the applicable standards for commercial or industrial devices (e.g. electromagnetic compatibility).

Note 2 to entry: Professional users include commercial or industrial customers.

3.2.9**utility EESS**

EES system which is integrated into the utility grid and serving solely to ensure safe and reliable operation of the *electric power network* (IEV 601-01-02)

[SOURCE: IEC 60050-631:2023, 631-01-05, modified – definition is reworded for better clarity.]

3.2.10**self-contained EES system**

EES system whose components have been matched and partially or totally assembled at the factory, that are shipped in one or more containers, and that are ready to be installed in the field

Note 1 to entry: For a definition of container, refer to IEC TS 62686-1:2020, 3.1.2.

3.2.11**stationary EES system**

EES system that, once installed and placed into service, is not intended to be moved from one place to another

[SOURCE: IEC 60601-1:2005 and IEC 60601-1:2005/AMD1:2, 3.118, modified – definition has been particularized for the EES system and the note to entry has been deleted.]

3.2.12**movable EES system**

EES system mounted on a vehicle capable of being moved on a railway or road, to be connected to primary POC at sites where temporary basis connection is planned

Note 1 to entry: The *portable* (IEV 151-16-47) concept cannot be applied to a grid connection installation like the EES system, therefore a movable EES system cannot include such situation.

[SOURCE: IEC 60050-811:2017, 811-36-05, modified – definition has been particularized for the EES system and the note to entry has been added.]

3.2.13**hybrid EES system**

EES system with an accumulation subsystem composed of different storage technologies

EXAMPLE Hybrid EESS that incorporates *batteries* (IEV 482-01-04) and *supercapacitors* (IEV 114-03-03).

3.3 EES systems long-duration application**3.3.1****long-duration application**

energy-intensive application

EES system application with long charge and discharge phases at variable powers

Note 1 to entry: Reactive power exchange with the *electric power system* (IEV 601-01-01) can be present along with the *active power* (IEV 131-11-42) exchange.

Note 2 to entry: Long-duration application are generally not very demanding in terms of step response performances but there are cases where high step response performances are required.

[SOURCE: IEC 60050-631:2023, 631-01-06 modified – alternate term deleted and part of the definition moved in the note 2.]

3.3.2**active power flow control**

<for an EES system> long-duration application of an EES system used to compensate partially or totally the *active power* (IEV 131-11-42) flow in a determined subsection of an *electric power system* (IEV 601-01-01)

EXAMPLE Load shaving or levelling or shifting are active power flow controls.

Note 1 to entry: Active power flow control can require hours of continuous EES system charge or discharge.

3.3.3**feeder current control**

<for an EES system> long-duration application of an EES system used to maintain the current in a certain grid branch within defined limits through *active power* (IEV 131-11-42) exchange with the *electric power network* (IEV 601-01-02)

EXAMPLE Congestion relief is a feeder current control.

Note 1 to entry: Theoretically, feeder current control can also be realised by *reactive power* (IEV 131-11-44) exchange. Because of typical distribution feeder characteristics such as the resistance-to-reactance ratio (R/X), the *active power* (IEV 131-11-42) exchange is practically more effective in most cases.

3.3.4**renewable energy resources generation firming**

long duration application of an EES system used to decouple non-dispatchable renewable energy source generation and electricity consumption for a specific time by absorbing energy in periods with a surplus of energy generation and by provision of energy in periods with a surplus of electricity consumption

3.3.5**peak shaving**

limitation of the power consumption from the power grid to a maximum value by providing the power exceeding the maximum value from other active power sources

3.3.6**fluctuation reduction of consumption**

reduction of power oscillation of power consumption at the grid connection point by absorbing the active power of the grid by EES systems at low power demand phases and by feeding in additional active power by EES systems at high power demand phases

3.4 EES systems short-duration application**3.4.1****short-duration application**

power intensive application

EES system application demanding in terms of step response performances and with frequent charge and discharge phase transitions or with *reactive power* (IEV 131-11-44) exchange with the *electric power system* (IEV 601-01-01)

[SOURCE: IEC 60050-631:2023, 631-01-07, modified – alternate term deleted and minor editorial modifications in the definition.]

3.4.2**grid frequency control**

power frequency control

frequency regulation

short-duration application of an EES system used for the stabilization of the *electric power system* (IEV 601-01-01) frequency through *active power* (IEV 131-11-42) exchange

Note 1 to entry: The balancing of temporal variations of grid frequency occurs typically over time periods of the order of seconds to minutes.

3.4.3**nodal voltage control**

voltage support

short-duration application of an EES system used for the stabilization of the voltage at the primary POC or neighbouring nodes through active or reactive power exchange

Note 1 to entry: *Reactive power* (IEV 131-11-44) is generally used in HV and MV grids, and *active power* (IEV 131-11-42) in LV grids, depending on the resistance-to-reactance (R/X) ratio of the relevant lines.

3.4.4**power quality event mitigation**

short-duration application of an EES system used to mitigate conducted disturbances in *electric power systems* (IEV 601-01-01) such as short-duration supply interruptions, voltage dips, voltage swells, voltage and currents harmonics, transient overvoltages, rapid voltage changes, through active or reactive power exchange with the *electric power network* (IEV 601-01-02)

Note 1 to entry: The mitigation of *power quality* (IEV 617-01-05) events, except supply interruptions and harmonics, occurs typically over time periods of the order of milliseconds to seconds. Power quality events are described in IEC TS 62749.

Note 2 to entry: In power quality event mitigation, active and reactive power exchange can be intended also in relation to harmonics and interharmonics.