

ISO TC 117/SC

ISO/FDIS 12759-1:2023(E)

2023-02-2404-13

ISO TC 117/SC /WG 11

Secretariat: BSI

Fans — Efficiency classification for fans — Part 1: General information for fans

Ventilateurs — Classification d'efficacité énergétique des ventilateurs

iTeh STANDARD PREVIEW
(standards.iteh.ai)

ISO 12759-1

<https://standards.iteh.ai/catalog/standards/sist/5d313ee8-dc76-4275-9264-ec0d4b431f8c/iso-12759-1>

~~Edited DIS -~~
~~MUST BE USED~~
~~FOR FINAL~~
~~DRAFT~~

Copyright notice

~~This ISO document is a Draft International Standard and is copyright protected by ISO. Except as permitted under 2023~~

~~All rights reserved. Unless otherwise specified, or required in the applicable laws context of the user's country, neither its implementation, no part of this ISO draft nor any extract from its publication may be reproduced, stored in a retrieval system or transmitted or utilized otherwise in any form or by any means, electronic, or mechanical, including photocopying, recording or otherwise or posting on the internet or an intranet, without prior written being secured.~~

~~Requests for permission to reproduce should. Permission can be addressed to requested from~~ either ISO at the address below or ISO's member body in the country of the requester.

~~ISO copyright office~~ Copyright Office
~~Case postale 56 • CP 401 • CH-1214 1214 Vernier, Geneva 20~~
~~Tel. Phone: + 41 22 749 01 11~~
~~Email: copyright@iso.org~~
~~Website: www.iso.org~~
~~Published in Switzerland.~~

~~Fax + 41 22 749 09 47~~

~~E-mail copyright@iso.org~~

~~Web www.iso.org~~

~~Reproduction may be subject to royalty payments or a licensing agreement.~~

iTeh STANDARD PREVIEW
(standards.iteh.ai)

ISO 12759-1

<https://standards.iteh.ai/catalog/standards/sist/5d313ee8-dc76-4275-9264-ec0d4b431f8c/iso-12759-1>

~~Edited DIS -~~
~~MUST BE USED~~
~~FOR FINAL~~
~~DRAFT~~

Contents

Foreword	6
Introduction	7
1 Scope	1
2 Normative references	1
3 Terms and definitions	1
3.1 Fan	2
3.2 Fan without drives	2
3.3 Driven fan	2
3.4 Impeller	2
3.5 Stationary element	2
3.6 Housing	2
3.7 Inlet guide vane	3
3.8 Outlet guide vane	3
3.9 Orifice ring	3
3.10 Orifice panel	3
3.11 Diffuser	3
3.12 Inlet cone	3
3.13 Nozzle	3
3.14 Fan without housing	3
3.15 Fan with housing	4
3.16 Measurement category	4
3.17 Measurement category A	4
3.18 Measurement category B	4
3.19 Measurement category C	4
3.20 Measurement category D	4
3.21 Measurement category E	4
3.22 Power	4
3.22.1 Efficiency	6
3.22.2 Efficiency category	7
3.23 Efficiency grade	7
3.24 Fan efficiency grade (FEG)	7
3.25 Fan motor efficiency grade (FMEG)	7
3.26 Jet fan motor efficiency grade (JFMEG)	7
3.27 Fan energy index (FEI)	8
3.28 Direct drive	8
3.29 Mechanical transmission	8
3.30 Drive	9
3.31 Maximum declared operating speed	9
3.32 Extended product	9
3.33 Nominal speed	10
4 Symbols and units	10
5 General requirements	10
5.1 General	10
5.2 Identify the fan type	11
5.3 Identify an appropriate installation category	11
6 Testing and calculation methods	12
6.1 General	12
6.2 Test method	12
6.3 Significant elements	13

6.4 Requirements of testing and calculation.....13

6.4.1 General.....13

6.4.2 Choice of testing or calculation method.....13

6.4.3 Full size, maximum declared operating speed testing on a standardised airway.....13

6.4.4 Testing using the scaling rules for fan performance.....14

6.4.5 Full size testing at modified speed on a standardised airway.....14

6.4.6 Subscale testing on a standardised airway.....14

6.5 Tolerances.....15

7 Ratings.....15

Annex A (informative) Protective guards.....16

Annex B (informative) Fan efficiency, energy effectiveness and specific fan power (SFP) ..20

B.1 Fan efficiency.....20

B.2 Air curtains.....20

B.3 Specific fan power (SFP).....20

Annex C (informative) The variation of fan performance between installation categories.....23

Bibliography.....24

Foreword.....6

Introduction.....7

1 Scope.....1

2 Normative references.....1

3 Terms and definitions.....1

Figure 1 — Power diagram of fan drive system.....6

Table 1 — Relationship between powers and efficiencies.....7

Figure 2 — Typical belt-driven fan.....9

4 Symbols and units.....10

5 General requirements.....10

5.1 General.....10

5.2 Identify the fan type.....11

5.3 Identify an appropriate installation category.....11

6 Testing and calculation methods.....12

6.1 General.....12

6.2 Test method.....12

6.3 Significant elements.....13

6.4 Requirements of testing and calculation13

6.4.1 General.....13

6.4.2 Choice of testing or calculation method.....13

6.4.3 Full-size, maximum declared operating speed testing on a standardised airway13

6.4.4 Testing using the scaling rules for fan performance.....14

6.4.5 Full-size testing at modified-speed on a standardised airway.....14

6.4.6 Subscale testing on a standardised airway.....14

6.5 Tolerances.....15

7 Ratings.....15

Annex A (informative) Protective guards.....16

Figure A.1 — Grid mounting, including protective element.....17

<u>Figure A.2 — Grid mounting with protective element removed.....</u>	<u>19</u>
<u>Annex B (informative) Fan efficiency, energy effectiveness and specific fan power (SFP) ..</u>	<u>20</u>
<u>B.1 Fan efficiency</u>	<u>20</u>
<u>B.2 Air curtains.....</u>	<u>20</u>
<u>B.3 Specific fan power (SFP).....</u>	<u>20</u>
<u>Annex C (informative) The variation of fan performance between installation categories</u>	<u>23</u>
<u>Bibliography</u>	<u>24</u>

iTeh STANDARD PREVIEW
(standards.iteh.ai)

ISO 12759-1

<https://standards.iteh.ai/catalog/standards/sist/5d313ee8-dc76-4275-9264-ec0d4b431f8c/iso-12759-1>

~~Edited DIS –~~
~~MUST BE USED~~
~~FOR FINAL~~
~~DRAFT~~

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

ISO draws attention to the possibility that the implementation of this document may involve the use of a patent(s). ISO takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, ISO had not received notice of a patent(s) which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at www.iso.org/patents. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT), see www.iso.org/foreword.html.

This document was prepared by Technical Committee ISO/TC 117, *Fans*.

A list of all parts in the ISO 12759 series can be found on the ISO website.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

~~Edited DIS –
MUST BE USED
FOR FINAL
DRAFT~~

Introduction

The last decade has seen an escalation in the price and an increasing recognition of the finite life of many of the fossil fuels currently used. This has led to many nations reviewing methods of energy generation and usage.

To maintain economic growth there is therefore a need to promote energy efficiency. This requires better selection of equipment by users and thus better design of this equipment by manufacturers.

Fans of all types are used for ventilation, air conditioning, process engineering – drying, pneumatic conveying – combustion air supply and agriculture. Indeed, the energy use of fans has been calculated to account for nearly 20 % of the global electricity usage.

The fan industry is global in nature, with a considerable degree of exporting and licensing. To ensure that the definitive fan performance characteristics are common throughout the world, a series of standards has been developed.

~~This deals with the classification of fan power consumption and efficiency for many fan types given in the ISO 12759 series. In addition, it details specific application efficiency classification information.~~

iTeh STANDARD PREVIEW
(standards.iteh.ai)

ISO 12759-1

<https://standards.iteh.ai/catalog/standards/sist/5d313ee8-dc76-4275-9264-ec0d4b431f8c/iso-12759-1>

~~Edited DIS –
MUST BE USED
FOR FINAL
DRAFT~~

Fans — Efficiency classification for fans — Part 1: General information for fans

1 Scope

This document deals with the classification of fan power consumption and efficiency for many fan types given in the ISO12759 series. In addition, it details specific application, efficiency classification information. These procedures are described in ISO 12759-3 ISO 12759-4 ISO 12759-5 and ISO 12759-6. ~~There is no~~ This document does not describe a method ~~described~~ to compare these classifications and minimum efficiency limits. ~~(MELs).~~

This document applies to the fans, not to the system in which they are installed.

Air curtains are excluded from this standard.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 5801:2017, *Fans — Performance testing using standardized airways*

ISO 5802, *Industrial fans — Performance testing in situ*

ISO 13348, *Industrial fans — Tolerances, methods of conversion and technical data presentation*

ISO 13349-1:2022, *Fans — Vocabulary and definitions of categories — Part 1: Vocabulary*

ISO 13349-2:2012, *Fans — Vocabulary and definitions of categories — Part 2: Categories*

ISO 13350, *Fans — Performance testing of jet fans*

ANSI/AMCA Standard 230-23, *Laboratory Methods of Testing Air Circulating Fans for Rating and Certification*

ANSI/AMCA Standard 260-20, *Laboratory Methods of Testing Induced Flow Fans for Rating*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 5801, ISO 13349-1 and ISO 13349-2 and the following apply.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <https://www.electropedia.org/>

3.1 Fan

3.1 fan

rotary bladed machine that receives mechanical energy and utilizes it by means of one or more impellers fitted with blades to maintain a continuous flow of air or other gas passing through it and whose work per unit mass does not normally exceed 25 kJ/kg

Note 1 to entry: The term “fan” is taken to mean the fan as supplied, without any addition to the inlet or outlet, except where such addition is specified.

Note 2 to entry: Fans are defined according to their installation category, function, fluid path and operating conditions.

Note 3 to entry: If the work per unit mass exceeds a value of 25 kJ/kg, the machine is termed a turbo-compressor. This means that, for a mean stagnation density through the fan of 1,2 kg/m³, the fan pressure does not exceed 1,2 × 25 kJ/kg, i.e. 30 kPa, and the pressure ratio does not exceed 1,30, since atmospheric pressure is approximately 100 kPa.

3.2 fan without drives

fan without a motor, a drive, an attachment or accessories

Note 1 to entry: Also known as a bare shaft fan.

[SOURCE: ISO 12759-3:2019]

3.3 driven fan

fan driven by an electrical motor.

Note 1 to entry: One or more impellers fitted to or connected to a motor with a stationary element, with or without transmission or variable speed drive (VSD), (ISO 13349).

3.4 impeller

rotating part of the fan that is imparting energy into the gas flow

3.5 stationary element

stationary part which interacts with the air stream passing through the impeller,

Note 1 to entry: It is an element, or a combination of elements, that interacts with the airstream directing and/or guiding the gas stream towards, through and/or from the impeller, an element may also assist in the conversion of energy

EXAMPLES: — Housing, — orifice ring, — orifice panel, — inlet bell (also known as venturi), inlet cone, inlet radius, inlet ring, inlet guide vane, outlet guide vane, outlet diffuser, nozzle.

Note 12 to entry: In some standards a stationary element is called a stator.

3.3 Housing

3.6 housing

stationary part which interacts with the air stream passing through the impeller

Note 1 to entry: A housing can be an element around the impeller which guides the gas stream towards, through and from the impeller.

Note 2 to entry: A housing can have additional parts included within or attached to it that affect the performance of the fan, such as inlet bell (also known as venturi), inlet cone, inlet radius, inlet ring, inlet guide vane, outlet guide vane or outlet diffuser.

Inlet3.7

inlet guide vane

vane positioned before the impeller to guide the gas stream towards the impeller

Note 1 to entry: The inlet guide vane can be adjustable.

Outlet3.8

outlet guide vane

vane positioned after the impeller to reduce the swirl from the impeller

Note 1 to entry: The outlet guide vane can be adjustable.

Orifice3.9

orifice ring

ring with an opening in which the fan sits and which allows the fan to be fixed to other structures

Note 1 to entry: An orifice is a plain hole in the physical partition (e.g. orifice panel) between the upstream and downstream airflow of the fan. It is a divide between the negative pressure and positive pressure areas that occur across the fan when there is a pressure difference between the fan inlet and fan outlet.

Orifice3.10

orifice panel

panel with an opening in which the fan sits and which allows the fan to be fixed to other structures

3.4 Diffuser

3.11

diffuser

device that improves the fan performance through static recovery

Inlet3.12

inlet cone

device that steers the air into the impeller and reduces the vena contracta and turbulence that can occur at a sharp edge of the housing

Note 1 to entry: Also known as venturi inlet, inlet bell or inlet radius.

3.5 Nozzle

3.13

nozzle

aperture or ajutage of the fan through which air or gas is discharged

Fan3.14

fan without housing

fan designed not to rely upon a housing for its correct operation

Note 1 to entry: Includes at least an impeller and a stationary element, such as an inlet cone.

[ISO/FDIS 12759-1:2023\(E\)](#)

~~Fan~~[3.15](#)

fan with housing

fan designed to rely upon a housing for its correct operation

~~Measurement~~[3.16](#)

measurement category

fan test configuration according to the arrangement of standardised test airways

Note 1 to entry: Also known as installation category, see ISO 5801 and ISO 13349.

~~Measurement~~[3.17](#)

measurement category A

installation with free inlet and free outlet with a partition

~~Measurement~~[3.18](#)

measurement category B

installation with free inlet and ducted outlet

~~Measurement~~[3.19](#)

measurement category C

installation with ducted inlet and free outlet

~~Measurement~~[3.20](#)

measurement category D

installation with ducted inlet and ducted outlet

~~Measurement~~[3.21](#)

measurement category E

installation with free inlet and free outlet without a partition

Note 1 to entry: Also known as test configuration category E. <https://standards.iteh.ai/catalog/standards/sist/5d313ee8-dc76-4275-9264-8c0d4b421f8c/iso-12759-1>

Note 2 to entry: For jet fans, ISO 13350 is used for determining product efficiencies.

Note 3 to entry: In this measurement category a fan cannot produce any static pressure rise.

[3.22](#)

~~3.6 — power~~**Power**

-
the amount of energy transferred or converted per unit of time

Note 1 to entry: The key in Figure 1 gives a fuller explanation to fan experts and non-fan experts on the losses within a fan system in terms that are understood by relevant industries.